



## **Fire Watch Instructions**

1. The fire department has been notified that a system is impaired and Fire Watch will be initiated.
2. The extent and expected duration of the impairment has been determined.
3. In the event of an emergency, an approved means of notifying the fire department has been provided.
4. An impairment coordinator has been assigned to comply with the requirements of out of service fire protection systems.
5. A fire watch inspector has been designated to perform constant patrols of the protected premises.
6. Supervisors in the areas affected have been notified.
7. The insurance carrier, the alarm company, building owner/manager and other authorities having jurisdiction have been notified.